

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20191858  
Address: 653 SW 2ND ST, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Final Building Inspection - Commercial</b>	John Borns	Partial	Tuesday, July 23, 2019

Corrective Action Required:

1	Misc	REPLACE ELECTRICAL PANEL SCHEDULE NEW ONE WITH UPDATED CIRCUIT LABELING.
---	------	--

Corrective Action Required:

2	Misc	RECENTLY INSTALLED WATER HEATER REQUIRES EXPANSION TANK
---	------	---

Corrective Action Required:

3	Misc	GFCI-PROTECTED ELETRICAL RECEPTACLE BELOW NEW SINK DOES NOT RE-SET.
---	------	---

**Comments:**