

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20191858
Address: 653 SW 2ND ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Building Inspection - Commercial	John Borns	Partial	Tuesday, July 23, 2019

Corrective Action Required:

1	Misc	REPLACE ELECTRICAL PANEL SCHEDULE NEW ONE WITH UPDATED CIRCUIT LABELING.
---	------	--

Corrective Action Required:

2	Misc	RECENTLY INSTALLED WATER HEATER REQUIRES EXPANSION TANK
---	------	---

Corrective Action Required:

3	Misc	GFCI-PROTECTED ELECTRICAL RECEPTACLE BELOW NEW SINK DOES NOT RE-SET.
---	------	--

Comments: