

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20183167
Address: 837 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Erosion Sediment Control (ESC) Inspection	Steve Robbins	Failed	Wednesday, July 24, 2019

Informational: 1	Misc	5-23-19 Silt fence is down in random spots of the job site. I called Jonathan Myers the project manager at 8:45am about the erosion control, he said he would address the problem areas.
Informational: 2	Misc	6-11-19 The silt fence is down on the south side of the site. The west side of the site has silt fence down and is missing sections completely. I will be emailing Jonathan Myers about the matter.
Informational: 3	Misc	7-24-19 10:22AM Silt fence is down on the west side of site along Ward RD. Silt fence is down along the north side of site along Tudor RD. As well. There is lots of silt on the sidewalks that needs cleaned up.

Comments: