

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20191251
Address: 1225 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial	John Borns	Partial	Wednesday, July 24, 2019

Partial Correction:

1	Misc	OK TO POUR WHEN READY: PERIMETER CONCRETE TRENCH FOOTING + INTEGRAL COLUMN FOOTINGS;
---	------	--

Comments: