## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #:PRPWFC20173801Address:3500 SW HOLLYWOOD DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:		Inspector:	Outcome:	Date:	
DE - Sidewalk Inspection		John DiMauro	Partial	Thursday, July 25, 2019	
Informational: 1 PW-Misc		John DiMauro 10/18/2018 1:50 PM			
		The crew has the sidewalk formed up for the section directly in front of Arvest Bank.			
		There appears to be sufficient compacted aggregate installed.		installed.	
Corrective Action Required:		I will return for further inspection after it has been poured.			
2	Misc	inspection. There are sec guidelines. Those section	n of the public sidewalk along SW Cheddington failed ere are sections of the sidewalk that do not meet ADA ose sections have a cross slope greater than 2.0 percent. ill need to be made to the sidewalk before acceptance.		
Informational:					
3	Misc	PRE POUR INSPECTION			
		along SW Cheddington. The forms are set and there a	Ik section at the northwest his sidewalk section will se opears to be sufficient com Il inspection at a later date.	rvice building 5. The pacted aggregate. I will	

**Comments:**