

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20191742
Address: 314 SW BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Borns	Partial	Thursday, July 25, 2019

Partial Correction:

1 Misc

OK TO COVER NEW AND MODIFIED WALLS AT [101]/[102] EXCEPT AT NW CORNER WHERE PVC PLUMBING PIPE IS NOT PROTECTED PER IPC 305.8. BOCA PLATE REQUIRED.

MODIFIED WALL AT DRINKING FOUNTAIN LOCATION NOT APPROVED TO COVER. PVC PLUMBING PIPE IS NOT PROTECTED PER IPC 305.8. SHIELD PLATES & BOCA PLATE REQUIRED.

Comments: