

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20191501  
Address: 4712 NE GATEWAY DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:            | Inspector:   | Outcome: | Date:                 |
|------------------------|--------------|----------|-----------------------|
| <b>Erosion Control</b> | Khanh Nguyen | Failed   | Friday, July 26, 2019 |

Corrective Action Required:

|   |      |                                                                                                                                                                                  |
|---|------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 1 | Misc | -EROSION CONTROL NOT INSTALLED PER CITY REQUIREMENT ALONG THE SIDE OF LOT ON THE SOUTH SIDE. REPAIR EROSION CONTROL AT NE CORNER.<br>-MUD AND DEBRIS SHALL BE CLEANED OFF STREET |
|---|------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|

**\*\*NO FURTHER INSPECTION UNTIL EROSION CONTROL IS IN COMPLIANCE**

**Comments:**