CITY OF LEE'S SUMMIT

Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20183471

Address: 420 NW MAIN ST, LEES SUMMIT, MO 64063

Inspected On: Friday, July 26, 2019

Inspected By: John Borns

Expiration Date: August 8, 2019

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection: Outcome: Date:

Occupancy Inspection - John Borns Temporary C of O Friday, July 26, 2019

Codes Residential

Corrective Action Required:

3 Misc LSCO #5029 PERMANENT EROSION CONTROL, VEGETATION, &

DRAINAGE GRADING PER PLOT PLAN: POSITIVE DRAINAGE ENTIRE LOT FINE GRADE, SOD/SEED LOT; 6" MIN CLEARANCE TO WOOD FRAMING, SHEATHING, SIDING, TRIM, STUCCO; 3`-0 SPLASH

BLOCKS OR LEADERS; UTILITY STRUCTURES AND ACCESS

PLUGS/COVERS SET TO FINISH GRADE; SEWER SERVICE TRACER PORT AT GRADE; AC CONDENSER PAD LEVEL & 3" ABOVE GRADE.