

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20190685
Address: 4501 SW NAUTILUS PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Piping Inspection - Residential	Jason McRoy	Failed	Friday, July 26, 2019

Corrective Action Required:

1	Misc	Terminate gas line to main floor and master bed fireplaces. Cannot use 100 psi gauge on gas line 30 psi max.
---	------	---

Comments: