

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary

Certificate of Occupancy

Permit #: **PRRES20183161**
Address: **3324 SW JESSIE LN, LEES SUMMIT, MO 64082**
Inspected On: **Friday, July 26, 2019**
Inspected By: **Brandon Kalwei**
Expiration Date: **8/26/2019 12:00:00 AM**

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Brandon Kalwei	Temporary C of O	Friday, July 26, 2019

Corrective Action Required:

1	Misc	Sod, final grade, splashblocks, sump pump discharge needs to be 36" from house
---	------	--

Make sure builder submits As-graded plot plan prior to sod to verify positive 2% drainage away from house and walkout.
Steven Conrick 12/12/2018 3:34 PM