

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20183171
Address: 1630 SW BLACKSTONE PL, LEES SUMMIT, MO 64082
Inspected On: Monday, July 29, 2019
Inspected By: Jason McRoy
Expiration Date: 8/29/2019 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Jason McRoy	Temporary C of O	Monday, July 29, 2019

Corrective Action Required:

- | | | |
|---|------|--|
| 1 | Misc | 1. DECK LEDGER BOARD ATTACHMENT NOT ALLOWED TO ATTACH TO CANTILEVER. DOUBLE HEADER AND DOUBLE BOTH SUPPORTING JOISTS . INSTALL JOIST HANGERS AT ALL. |
| | | 2. PROVIDE AS GRADED PLOT PLAN PRIOR TO SOD. |