

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20181582
Address: 2544 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Brandon Kalwei	Failed	Tuesday, July 30, 2019

Corrective Action Required:

1	Misc	-security screws for rear door hinges needed -handrail for deck needs to be code compliant, 2x6 not allowed -sod, splash blocks, final grade -water main copper piping in basement needs to be secured -railing needed on SW side of front porch
---	------	--

Comments: