

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20191819
Address: 1208 NE GOSHEN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Residential	John Borns	Passed	Tuesday, July 30, 2019

Comments: OK TO POUR WHEN READY WALL & COLUMN FOOTINGS. UFER GROUNDING JUMPER IN PLACE AT WEST WALL.