

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20190156
Address: 3336 SW JESSIE LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Sidewalk Inspection	Marquelle Williams	Passed	Tuesday, July 30, 2019

Corrective Action Required:

1	Misc	PRE POUR INSPECTION
---	------	---------------------

SIDEWALK FAILS

At time of inspection, all forms meet Lees Summit and ADA spec. Gravel is present, BUT CONTRACTOR MUST HAVE THE PROPER AMOUNT OF GRAVEL THROUGH OUT SIDEWALK.

Informational:

2	Misc	PRE POUR RE-INSPECT
		PRE POUR RE-INSPECT PASSED

JULY 25, 2019

Contractor contacted inspector to let inspector know that he re formed only to the property line of 3336 SW Jessie LN. Forms are with in Lees Summit and ADA specs. Contractor also put more of the correct size of clean gravel down and Re compacted.

Informational:

3	Misc	JULY 30, 2019
		POST POUR INSPECTION

Sidewalk meet all ADA and Lees Summit spec.

Comments: