



PLAN REVIEW CONDITIONS

July 30, 2019

ACI BOLAND
1421 EAST 104TH ST; SUITE 100
KANSAS CITY, MO 64131

Permit No: PRCOM20191770
Project Title: LEES SUMMIT SURGICAL - AMBULATORY SURGERY FACILITY
Project Address: 2801 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064
Parcel Number: 52200013900000000
Location: I-470 BUSINESS & TECHNOLOGY CENTER LOT 15A---LOT 15A
Type of Work: NEW TENANT FINISH
Occupancy Group:
Description: TENANT FINISH FOR AMBULATORY SURGERY FACILITY

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Development Services Department (816) 969-1200

Fire Department (816) 969-1300

Fire Plan Review

Reviewed By: Michael Weissenbach

Approved with Conditions

1. 2018 IFC 907.1.1- Construction documents. Construction documents for fire alarm systems shall be submitted for review and approval prior to system installation. Construction documents shall include, but not be limited to, all of the following: 1. .A floor plan which indicates the use of all rooms. 2. Locations of alarm-initiating and notification appliances. 3. Alarm control and trouble signaling equipment. 4. Annunciation. 5. Power connection. 6. Battery calculations. 7. Conductor type and sizes. 8. Voltage drop calculations. 9. Manufacturers, model numbers and listing information for equipment, devices and materials. 10. Details of ceiling height and construction. 11. The interface of fire safety control functions.

(Action Required)

Provide three engineered stamped sets of shop drawings for the Fire Alarm System.

2. 2018 IFC 407.3- Identification. Individual containers of hazardous materials, cartons or packages shall be marked or labeled in accordance with applicable federal regulations. Buildings, rooms and spaces containing hazardous materials shall be identified by hazard warning signs in accordance with Section 2703.5.

(Informational Purposes)

3. 2018 IFC 403.11.1.5 - Tenant identification. Each occupied tenant space provided with a secondary exit to the exterior or exit corridor shall be provided with tenant identification by business name and/or address. Letters and numbers shall be posted on the corridor side of the door, be plainly legible and shall

contrast with their background.
(Verified At Inspection)
Label all rooms/spaces

4. 2018 IFC 510.1- Identification. Fire protection equipment shall be identified in an approved manner. Rooms containing controls for air-conditioning systems, sprinkler risers and valves, or other fire detection, suppression or control elements shall be identified for the use of the fire department. Approved signs required to identify fire protection equipment and equipment location, shall be constructed of durable materials, permanently installed and readily visible.

(Action Required)

Fire sprinkler plans have been submitted and approved for the shell. Any modifications to the system, provide three engineered stamped sets of shop drawings.

7. 2018 IFC 1010.1.9 Door operations. Except as specifically permitted by this section, egress doors shall be readily openable from the egress side without the use of a key or special knowledge or effort.

(Informational Purposes)

Building Plan Review

Reviewed By: Joe Frogge

Rejected

1. This project is associated with an open shell permit.

Action required: Comment is for informational purposes. Occupancy shall not be granted until shell occupancy has been granted.

7/26/19 - acknowledged in letter

2. The project cost, which is used to establish the permit fee, has not been provided.

Action required: Comment is for informational purposes.

7/26/19 - acknowledged in letter

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.