

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20191528  
Address: 3102 SE 3RD TER, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Brandon Kalwei	Failed	Wednesday, July 31, 2019

Corrective Action Required:

1	Misc	-no city approved stamped plans on site -joists hangers are under sized for 2x10 rafters, install proper sized hangers - work has been covered up, cannot see carriage bolts or how rafters are connected to beams -electrical permit needs to be pulled with licensed electrician
---	------	---

**Comments:**