

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20191818
Address: 1204 NE GOSHEN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Residential	John Borns	Passed	Wednesday, July 31, 2019

Comments: OK TO POUR WHEN READY WALL FOOTINGS & ISOLATED FOOTINGS. UFER GROUNDING JUMPER IS IN PLACE AT SW CORNER. ENSURE *MINIMUM 3" CLEARANCE FROM RE-BAR TO BOTTOMS & BANKS*. PER ACI 318 DO NOT POUR CONCRETE ON SUBGRADE WITH STANDING WATER.