CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #:	PRRES20190113
Address:	2005 NE BLUESTONE DR, LEES SUMMIT, MO 64064
Inspected On:	Thursday, August 01, 2019
Inspected By:	John Borns
Expiration Date:	October 3, 2019

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	John Borns	Temporary C of O	Thursday, August 01, 2019

Corrective Action Required:

2 Misc LSCO #5029 PERMANENT EROSION CONTROL, VEGETATION, & DRAINAGE GRADING PER PLOT PLAN: POSITIVE DRAINAGE ENTIRE LOT FINE GRADE, SOD/SEED LOT; 6" MIN CLEARANCE TO WOOD FRAMING, SHEATHING, SIDING, TRIM, STUCCO; UTILITY STRUCTURES AND ACCESS PLUGS/COVERS SET TO FINISH GRADE; SEWER SERVICE TRACER PORT AT GRADE;..