

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20190520  
Address: 4729 NE GATEWAY DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                     | Inspector:   | Outcome: | Date:                     |
|---------------------------------|--------------|----------|---------------------------|
| <b>DE - Sidewalk Inspection</b> | John Jackson | Partial  | Thursday, August 01, 2019 |

Corrective Action Required:

|   |                |   |
|---|----------------|---|
| 1 | Misc           | Rebar installed without chair lifts which helps to properly reinforce sidewalk .        |
| 2 | Informational: | Contractor corrected issue and Sidewalk - forms and materials passed pre - inspection . |

**Comments:**