

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20190654

Address: 2030 NW OBRIEN RD, LEES SUMMIT, MO 64081500 NW PRYOR RD, LEES SUMMIT, MO 64081450
NW PRYOR RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Sanitary - Material Verification	Ronald Paynter	Passed	Wednesday, July 17, 2019

Informational:

1 Misc

8 inch sanitary pipe is SDR26 manufactured by North American Pipe Corporation. 4 inch service laterals are also SDR26. 8 inch ductile sanitary pipe is C50 manufactured by McWane Ductile. Manholes were manufactured by Barbour Concrete Company. The steps are model ML-13-NCR. Sewer lids are model 1502A. RP 7-16-19

Comments: