

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20181920
Address: 253 NW KESSLER DR, Unit:MAINT, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Commercial	Mark Harding	Partial	Friday, August 02, 2019

Corrective Action Required:

1	Misc	partial - clean out needed within 5' in or outside of building
---	------	--

Comments: