

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20191745
Address: 2101 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Water Line - Construction Inspection	John Jackson	Passed	Friday, August 02, 2019

Informational:

1

Contractor installed a 6" DIP sleeve from existing 6" PVC to the newly installed 6" PVC , Approximately 4' of PVC then 6" DIP 45 deg bend ,Approximately 40' of PVC and 6" DIP 45 deg bend, & Approximately 36' of PVC and the existing hydrant was reinstalled on line . All DIP fitting were mega lugged .

Comments: