

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSITE20191745  
Address: 2101 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>DE - Water Line - Construction Inspection</b>	John Jackson	Partial	Thursday, August 01, 2019

Informational:

1

Contractor installed a 6" DIP sleeve from existing 6" PVC to the newly installed 6" PVC , Approximately 4' of PVC then 6" DIP 45 deg bend ,Approximately 40' of PVC and 6" DIP 45 deg bend, & Approximately 36' of PVC and the existing hydrant was reinstalled on line . All DIP fitting were mega lugged .

**Comments:**