

Inspection Summary

Permit #: PRCOM20181920, Building Permit - Commercial
MERIDIAN AT VIEW HIGH - GARAGE FOUNDATION
Address: 253 NW KESSLER DR, Unit:MAINT, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Commercial	Mark Harding	Partial	Friday, August 02, 2019

Corrective Action Required

1 partial - clean out needed within 5' in or outside of building

Sewer Service Inspection - Commercial	Steve Robbins	Passed	Friday, August 02, 2019
--	---------------	--------	-------------------------------

Informational

1 The connection for the service line to the main has been made and looks good. Steve Robbins 08/02/2019 3:33 PM

Comments: