

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20190520
Address: 4729 NE GATEWAY DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	John Jackson	Partial	Thursday, August 01, 2019

Corrective Action Required:

1	Misc	Length of driveway approach over 36' .
2	Informational:	Contractor corrected the length of driveway to be under 36' Driveway - forms and materials passed pre-inspection.

Comments: