

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20190520
Address: 4729 NE GATEWAY DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Sidewalk Inspection	John Jackson	Partial	Thursday, August 01, 2019

Corrective Action Required:

1	Misc	Rebar installed without chair lifts which helps to properly reinforce sidewalk .
---	------	--

Informational:

2	Contractor corrected issue and Sidewalk - forms and materials passed pre - inspection .
---	---

Comments: