## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

## **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #: PRRES20183409

Address: 1320 NE BRANDYWINE RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - Codes John Borns Failed Monday, August 05,

Residential 2019

Corrective Action Required:

1 Misc LSCO #5029 PERMANENT EROSION CONTROL, VEGETATION, & DRAINAGE

GRADING PER PLOT PLAN: POSITIVE DRAINAGE ENTIRE LOT FINE GRADE, SOD/SEED LOT; 6" MIN CLEARANCE TO WOOD FRAMING, SHEATHING, SIDING, TRIM, STUCCO; 3'-0 SPLASH BLOCKS OR LEADERS; UTILITY STRUCTURES AND ACCESS PLUGS/COVERS SET TO FINISH GRADE; SEWER SERVICE TRACER PORT

AT GRADE; AC CONDENSER PAD LEVEL & 3" ABOVE GRADE.

Corrective Action Required:

4 Misc TEMPORARY EROSION CONTROL REQUIRED FOR TCO TO BE ISSUED

**Comments:**