## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #:PRRES20183816Address:4513 SW NAUTILUS PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	John DiMauro	Passed	Monday, August 05, 2019
Corrective Action Required:			
1 Misc	POST POUR INSPECTION		
Informational:	The driveway approach has a cross slope greater than 2.0 percent. Corrective action is required. Photos are attached.		
2 Misc	PRE POUR INSPECTION		
	The forms are set and there appears to be sufficient compacted aggregate.		
3 Misc	PRE POUR INSPECTION		
	The drive approach that was out of ADA compliance was torn out and is now formed for replacement.		
	The forms are set and there appears to be sufficient compacted aggregate.		

Comments: