

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20181463  
Address: 4712 NE POCONO CIR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>DE - Sidewalk Inspection</b>	John Jackson	Partial	Tuesday, August 06, 2019

Informational:

1 Misc

Sidewalk- forms, materials, and grading passed pre-inspection .  
I left a reminder note for contractor to ensure landing area behind ADA ramp was at 1.5 % in cross section & longitude direction. Contractor will complete the installation of epoxy dowels for curb before concrete pour .

**Comments:**