CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20190685 Address: 4501 SW NAUTILUS PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:		Inspector:	Outcome:	Date:
Gas Piping Inspection - Residential		Jason McRoy	Failed	Tuesday, August 06, 2019
Corrective Action Required:				
1	Misc	Terminate gas line to main floor and master bed fireplaces.		
Cannot use 100 psi gauge on ga		on gas line 30 psi max.		
Corrective Action Required:				
2 Misc Terminate gas line to main floor and master bed fi			n floor and master bed firep	places.
		Cannot use 100 psi gauge on gas line 30 psi max.		

Comments: