

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816) 969-1200 FAX (816) 969-1201

# Temporary Certificate of Occupancy

---

**Permit #:** PRRES20183692  
**Address:** 4063 NE TIMBERLAKE CT, LEES SUMMIT, MO 64064  
**Inspected On:** Tuesday, August 06, 2019  
**Inspected By:** John Borns  
**Expiration Date:** October 3, 2019

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	John Borns	Temporary C of O	Tuesday, August 06, 2019

**Corrective Action Required:**

1	Misc	LSCO #5029 PERMANENT EROSION CONTROL, VEGETATION, & DRAINAGE GRADING PER PLOT PLAN: POSITIVE DRAINAGE ENTIRE LOT FINE GRADE, SOD/SEED LOT; 6" MIN CLEARANCE TO WOOD FRAMING, SHEATHING, SIDING, TRIM, STUCCO; 3'-0" SPLASH BLOCKS OR LEADERS; UTILITY STRUCTURES AND ACCESS PLUGS/COVERS SET TO FINISH GRADE; SEWER SERVICE TRACER PORT AT GRADE; AC CONDENSER PAD LEVEL & 3" ABOVE GRADE.
---	------	--