

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20190858
Address: 350 SW BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	John Borns	Failed	Wednesday, August 07, 2019

Corrective Action Required:	
1 Misc	REMOVE ALL ABANDONED MATERIAL: FRAMING MEMBERS; HANGERS; ETC
Corrective Action Required:	
2 Misc	RESTORE MISSING OR DISPLACED WALL INSULATION
Corrective Action Required:	
3 Misc	DISCONTINUOUS DUCTS AT NORTH WALL??
Corrective Action Required:	
4 Misc	UNIDENTIFIED COPPER TUBE WITH PARTIAL INSULATION??
Corrective Action Required:	
5 Misc	SECURE MC ELECTRICAL CABLE WITHIN 12" OF ENTRY TO BOXES WHEREVER POSSIBLE
Corrective Action Required:	
6 Misc	1ST LAYER OF GREASE DUCT WRAP WAS COVERED BEFORE INSPECTION.

Comments: