## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

## **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #: PRCOM20190858

Address: 350 SW BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Hood/Duct Inspection John Borns Partial Thursday, August 08,

2019

**Partial Correction:** 

1 Misc LIGHT TEST OF GREASE DUCT AT EAST AND WEST HOODS. DUCT WAS

INSTALLED WITHOUT LIGHT TEST OF SHOP WELDS.

NO HOLES FOUND ON DUCT AT EAST HOOD.

AT WEST HOOD UPPER 36" WAS NOT ACCESSIBLE FOR LIGHT TEST. NO HOLES

FOUND BELOW THAT ELEVATION.

**GREASE DUCT WRAP 1ST LAYER OK TO APPLY 2ND WRAP BOTH HOODS** 

Corrective Action Required:

2 Misc IMC 507.16 COMMERCIAL KITCHEN GREASE HOOD PERFORMANCE TEST:

NEBB-CERTIFIED REPORT REQUIRED TO BE SUBMITTED TO INSPECTOR WHEN

EQUIPMENT IS OPERATIONAL AND BEFORE COMMERCIAL USE. SMOKE CAPTURE TEST TO BE CERTIFIED BY 3RD PARTY OR WITNESSED BY INSPECTOR

BEFORE ANY USE IS APPROVED.

**Comments:**