

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20191192
Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Building Inspection - Commercial	John Borns	Partial	Thursday, August 08, 2019

Partial Correction:

1	Misc	PHASES 1&2 AREAS 1A017 & 1A022A SUBSTANTIALLY COMPLETED. CASEWORK INSTALLATION IN PROGRESS. BACKFLOW PROTECTION REQUIRED FOR SOFT DRINK EQUIPMENT
---	------	---

Comments: