

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20183800  
Address: 4509 SW NAUTILUS PL, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Jason McRoy	Failed	Thursday, August 08, 2019

Corrective Action Required:

1	Misc	Install handles and locks on rear sliding glass doors, also a secondary locking device. Install all window crank handles on 2nd fl. Install handles and led and secondary locking device at basement sliding glass doors. Finish install guard railing at back deck stairs. Seal penetration for sump discharge, and extend discharge min 36" away from foundation. Seal exterior gas line penetration. Secure raceway at electric meter. Final grading. Sod. Splash blocks Address. Obtain irrigation permit, and backflow certificate.
---	------	---

Comments: