

PLAN REVIEW CONDITIONS

August 08, 2019

SCHARHAG ARCHITECTS 6247 BROOKSIDE BLVD STE 204 KANSAS CITY, MO 64113

Permit No: PRCOM20192128
Project Title: AMERICAN HEARING

Project Address: 1002 SW BLUE PKWY, LEES SUMMIT, MO 64063

Parcel Number: 61330168900000000

Location: RNG-31 TWP-47 SEC-06 PT SW 1/4 DAF: BEG AT A PT 1150' W OF SE COR SD SW 1/4 TH N 28'

M/L TO N ROW LI OF 3RD ST & TRU POB TH CONT N 220' TH E 130' TO SW COR LOT 58 ROBIN

HILLS TH N 125' TO S ROW LI OF

Type of Work: CHANGE OF TENANT

Occupancy Group: BUSINESS

Description: TENANT FINISH FOR HEARING AID SERVICE

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Development Services Department (816) 969-1200 Fire Department (816) 969-1300

Building Plan Review Reviewed By: Joe Frogge Pending

Fire Plan Review Reviewed By: Michael Weissenbach Approved

1. 2018 IFC 505.1- Address numbers. New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. In Multi-tenant commercial building where tenants have multiple entrances located on different sides of the building, each door shall be addressed. Address numbers shall be Arabic numerals or alphabet letters. Numbers shall be a minimum of 4 inches (102 mm) high with a minimum stroke width of 0.5 inch (12.7 mm).

(Verified At Inspection)

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.