

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20190968
Address: 701 NW WARD RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Sanitary Sewer - Mandrel	John Jackson	Passed	Friday, August 09, 2019

Corrective Action Required:

1	Misc	Mandrel failed to travel through A2 to A1 & A3 to A2. Contractor will correct problem so mandrel test can be done later. Mandrel was able to successfully travel through A1 to Existing Manhole.
---	------	--

Informational:

2	Misc	8-9-19 8:13am The mandrel has been verified and we pulled from A-2 to A-1 it passed. We are now pulling from A-3 to A-2 it passed as well.
---	------	--

Comments: