

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20191458  
Address: 3680 NE AKIN DR, Unit:102, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	Khanh Nguyen	Failed	Friday, August 09, 2019

Corrective Action Required:

1	Misc	-FIRE DEPT APPROVAL REQUIRED -INSTALL NO SMOKING SIGNAGE AT FRONT -INSTALL SPARK RINGS FOR ALL ELECTRICAL BOXES RECESSED MORE THAN 1/4" BEHIND NON-COMBUSTIBLE WALL SURFACE -RECEPTACLES AT HAIR WASH SINKS MUST BE GFCI-PROTECTED -RECEPTACLE IN LAUNDRY RM LOCATED WITHIN SIX FT OF THE SINK MUST BE GFCI-PROTECTED -INSTALL ROOF FLASHING FOR THE 3" PLUMBING VENT PER CODE. CANNOT SIMPLY CAULK AROUND IT -INSTALL MIN CIRCUIT AMPACITY FOR THE RTU PER LABEL
---	------	---

\*\*OK TO STOCK ITEMS

**Comments:**