

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20191552
Address: 500 SW MARKET ST, Unit:E, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Failed	Friday, August 09, 2019

Corrective Action Required:

1	Misc	TEMPORARY PLEXIGLASS AT ENTRY DOOR TO BE REPLACED WITH TEMPERED GLAZING
---	------	---

Corrective Action Required:

2	Misc	CHECK ALL ELECTRICAL RECEPTACLES TO ENSURE ALL ARE MOUNTED SOLID TO BOX -- NONE "SOFT" OR LOOSE SIDE-TO-SIDE. USE YOKE SPACERS OR BOX EXTENDERS WHERE NEEDED. CHECK OPERATION OF GFCI ELECT RECEPT ABOVE WATER CLOSET. REPLACE IF NECESSARY.
---	------	---

Corrective Action Required:

3	Misc	OBTAIN FIRE DEPT APPROVAL
---	------	---------------------------

Comments: ABOVE-CEILING INSPECTION APPROVED.