

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20182736  
Address: 2505 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Brandon Kalwei	Failed	Monday, August 12, 2019

Corrective Action Required:

1	Misc	># braced wall panels great room wall at top plates first floor . ((header straps incorrect ># Ceiling Joist 24"oc. Support per code or install at 16" oc. incomplete >#> Fire stop angle wall at stairs solid material not loose insulation . incomplete >#flue Clearance second floor. ># install solid blocking not loose insulation for fire stop. ># Leg over master bathroom to ridge is over 45°. > solid block cantilevers in basement and block over I-beams in basement. block all bearing locations, south side ># install studs directly under stair joist basement wall .
---	------	---

**Comments:**