

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20182738
Address: 2606 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|----------------|----------|-------------------------|
| All Rough Inspection - Residential | Brandon Kalwei | Failed | Monday, August 12, 2019 |

Corrective Action Required:

| | | |
|---|------|---|
| 1 | Misc | **fire stop flue chase in garage vertical to horizontal, fire blocking insulation loose, need solid blocking #install wall receptacles with 6' of door and any wall 24" , see 2nd floor bedrooms. INCOMPLETE #install solid block at flue chase 2nd floor front side. do not cover INCOMPLETE wood incontact with flue. *ok to insulate |
|---|------|---|

Comments: