

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20182736
Address: 2505 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Brandon Kalwei	Failed	Monday, August 12, 2019

Corrective Action Required:

1	Misc	># braced wall panels great room wall at top plates first floor . ((header straps incorrect >#> Fire stop angle wall at stairs solid material not loose insulation . incomplete >#flue Clearance second floor. ># install solid blocking not loose insulation for fire stop. ># Leg over master bathroom to ridge is over 45°. Will clarify
---	------	---

Comments: