

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20190968
Address: 701 NW WARD RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Sanitary Sewer - Vacuum	John Jackson	Passed	Monday, August 12, 2019

Informational:

1 Misc

Informational:

2 Misc

Informational:

3 Misc

Informational:

4 Misc

Vacuum test passed on line A for Manhole A1,A2 ,& A3.

Vacuum test passed on line A for Manhole A1,A2 ,& A3.

8-12-19 1:37pm They are setting up for the vacuum test with a brand new gauge on manhole B-1. It has held vacuum for two minutes.

Comments: