

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRCOM20191458
Address: 3680 NE AKIN DR, Unit:102, LEES SUMMIT, MO 64064
Inspected On: Monday, August 12, 2019
Inspected By: Khanh Nguyen
Expiration Date: 9/12/2019 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Khanh Nguyen	Temporary C of O	Monday, August 12, 2019

Corrective Action Required:

1	Misc	-INSTALL ROOF FLASHING FOR THE 3" PLUMBING VENT PER CODE. CANNOT SIMPLY CAULK AROUND IT
---	------	--