

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20181463
Address: 4712 NE POCONO CIR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DE - Sidewalk Inspection	John Jackson	Passed	Tuesday, August 13, 2019

Informational:
1 Misc Sidewalk- forms, materials, and grading passed pre-inspection .
I left a reminder note for contractor to ensure landing area behind ADA ramp was at 1.5 % in cross section & longitude direction. Contractor will complete the installation of epoxy dowels for curb before concrete pour .

Informational:
2 Misc Final inspection passed. Contractor was over the 2" to the side for the warning mat.

Comments: