

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20191460	Date:	August 14, 2019
Project Title:	VISONI SALON & STUDIOS	Applicant:	
Location:			
1160 NE DOUGLAS ST, LEES SUMMIT, MO 64086		ALLIANCE FIRE PROTECTION LLC	
Type of Work:		130 W 9TH AVE STE 101	
Occupancy Group:	B	KANSAS CITY, MO 64116	
Description:	TENANT FINISH FOR HAIR SALON		
Construction Type:	Type VB (Unprotected)	Primary:	(913) 888-0647
Map Page:	195B		

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Michael Weissenbach

Released for Construction

1. 2018 IFC 901.6- Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be maintained in an operative condition at all times, and shall be replaced or repaired where defective. Not required fire protection systems and equipment shall be inspected, tested and maintained or removed.

(Action Required)

Maintain sprinkler system during construction.

Current annual tag on riser.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.