

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20190941  
Address: 4520 SW NAUTILUS PL, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Brandon Kalwei	Failed	Thursday, August 15, 2019

Corrective Action Required:

1	Misc	-2 hurricane straps missing in front bedroom, left side of door -in master bedroom north side, strap top plates above where it says "make flush" -support firred our ceiling in basement every 3' OK to insulate
---	------	---

**Comments:**