

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20192216
Address: 2807 NW CHIPMAN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Residential	John Borns	Passed	Friday, August 16, 2019

Comments: USE DE-OX AT CABLE TERMINATIONS IF RECOMMENDED BY CABLE MANUFACTURER. NO CODES ISSUES FOUND AT NEW POINT OF SERVICE. RELEASE SERVICE FOR METER. PERMIT CLOSED.