

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20180348  
Address:

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>DE - ADA Inspection</b>	John DiMauro	Passed	Monday, August 19, 2019

Informational:  
1 Misc JK Concrete is on site installing the ADA ramps and a section of the public sidewalk for the subdivision. I inspected the ramp forms and verified the subgrade is in compliance. I will return for further inspection after the concrete has been poured.

Informational:  
2 Misc The ADA Ramps are in compliance.

**Comments:**