

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20172507
Address: 213 NW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Mark Harding	Partial	Monday, August 19, 2019

Corrective Action Required:

1	Misc	Pre-rock 3 floors ok Dryer boxes 3 floors ok. Fire collars ok Ready for units pending rough approval
---	------	---

Corrective Action Required:

2	THE FOLLOWING AREAS ARE APPROVED	RC CHANNEL ALL ROOMS EXCEPT FOYER AND STAIR TOWERS UNITS - ok
---	--	--

Comments: